# APPLICATION FOR OSHPD SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP) APPLICATION #:** OSP - 0549 - 10 **OSHPD Special Seismic Certification Preapproval (OSP)** New □ Renewal **Manufacturer Information** ait-deutschland GmbH Manufacturer: Manufacturer's Technical Representative: Markus Zobler Mailing Address: Industriestrasse 3; 95359 Kasendorf Telephone: +49-9228-9906-1580 Email: markus.zobler@ait-deutschland.eu **Product Information** Product Name: cBoxX 100 Compact Chiller and Chiller Interface Panel (CIP) Product Type: Water Chiller Product Model Number: See Attachment (List all unique product identification numbers and/or part numbers) General Description: Chiller system for cooling fluid using air cooled refrigerant Mounting Description: Flexible floor mounted chiller and rigid wall mounted Chiller Interface Panel (CIP) **Applicant Information** Applicant Company Name: W.E. Gundy & Associates, Inc. Contact Person: Travis Soppe, SE Mailing Address: 250 Bobwhite Ct, Suite 100, Boise, ID 83706 Email: tsoppe@wegai.com Telephone: (208) 342-5989 Ext 115 I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016. Signature of Applicant: Date: 01-24-2018 Company Name: W.E. Gundy & Associates, Inc.

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs'





Page 1 of 3

OFFICE USE ONLY

Camornia Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name:W.E. Gundy & Associates, Inc.
Name: Travis Soppe, SE California License Number: S6115
Mailing Address: 205 Bobwhite Ct, Suite 100, Boise, ID 83706
Telephone: (208) 342-5898 Ext. 115 Email: <u>tsoppe@wegai.com</u>
Supports and Attachments Preapproval
Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
Supports and attachments are not preapproved
Certification Method
<ul> <li>☐ Testing in accordance with:</li> <li>☐ Other (Please Specify):</li> </ul>
Testing Laboratory
Company Name: IABG mbH
Contact Name: Dr. Steffen Roedling
Mailing Address: Einsteinstrasse 20, Ottobrunn, Germany D-85521
Telephone:+49 (0) 89 / 6088-2052





# OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters								
Design in accordance with ASCE 7-10 Chapter 13: ⊠ Yes □ No								
Design Basis of Equipment or Components (F <sub>p</sub> /W <sub>p</sub> ) = See Attachment								
S <sub>DS</sub> (Design spectral response acceleration at short period, g) = 2.00 (z/h = 1); 2.50 (z/h = 0)								
a <sub>p</sub> (In-structure equipment or component amplification factor) = 2.5								
R <sub>p</sub> (Equipment or component response modification factor) = See Attachment								
$\Omega_0$ (System overstrength factor) =2.0								
I <sub>p</sub> (Importance factor) = 1.5								
z/h (Height factor ratio) = $1 (S_{DS} = 2.00)$ ; $0 (S_{DS} = 2.50)$								
Equipment or Component Natural Frequencies (Hz) = See Attachment								
Overall dimensions and weight (or range thereof) = See Attachment								
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15:   Yes  No								
Design Basis of Equipment or Components (V/W) =								
S <sub>DS</sub> (Design spectral response acceleration at short period, g) =								
S <sub>D1</sub> (Design spectral response acceleration at 1 second period, g) =								
R (Response modification coefficient ) =								
$\Omega_0$ (System overstrength factor) =								
C <sub>d</sub> (Deflection amplification factor) =								
I <sub>P</sub> (Importance factor) = 1.5								
Height to Center of Gravity above base =								
Equipment or Component Natural Frequencies (Hz) =								
Overall dimensions and weight (or range thereof) =								
Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☐ No								
List of Attachments Supporting Special Seismic Certification								
Other(s) (Please Specify): Certified System Matrix, UUT Summary Sheets, Subcomponent Certification Letter								
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022								
Signature: Date: May 14, 2018								
77-47/20								
Print Name:Timothy J. Piland Title: Title: See Above 7/b See Above								
Special Seismic Certification Valid Up to : $S_{DS}(g) = \underline{See \ Above}$ $z/h = \underline{See \ Above}$ Condition of Approval (if applicable):								
Condition of Approval (ii applicable).								

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





Page 3 of 3

# KKT Chillers - AIT Deutschland GmbH SPECIAL SEISMIC CERTIFICATION CERTIFIED SYSTEM AND COMPONENTS



Manufacturer: KKT Chillers - AIT Deutschland GmbH

**System:** cBoxX 100 Compact Chiller System

	Siemens	Dimensions (in)			Weight	Mounting	UUT
System Component <sup>1</sup>	Part Number	Width	Depth	Height	(lb)	Mounting	001
cBoxX 100 <sup>3</sup>	909100-00469	32.7"	72.4"	79.9"	1740 <sup>2</sup>	flexible floor	UUT-1
Chiller Interface Panel (CIP)	909000.0107	13.6"	25.4"	52.2"	171	rigid wall	UUT-2

<sup>&</sup>lt;sup>1</sup> All components are manufactured by AIT Deutschland GmbH unless noted. The part numbers listed uniquely identify the type of component, manufacturer, and material of construction for each sub-componenent within the tested units.

<sup>&</sup>lt;sup>3</sup> cBoxX100 shall include added base plate assembly (AIT drawing P6856-0020) to address anomolies observed during test.

SEISMIC CERTIFICATION LIMITS									
System Component	Code	$S_{DS}(g)$	<b>z</b> / <b>h</b>	$I_P$	a <sub>P</sub>	$R_{P}$	$\Omega_0$	$\mathbf{F}_{\mathbf{P}} / \mathbf{W}_{\mathbf{P}}$	
cBoxX 100	CBC 2016 ASCE 7-10	2.0	1.0	1.50	2.5	2.5	2.0	3.60	
		2.5	0					1.50	
Chiller Interface Panel		2.0	1.0	1.50	2.5	6.0	2.0	1.50	
(CIP)		2.5	0					1.13	

<sup>&</sup>lt;sup>2</sup> Weight includes normal operating fluid used during seismic test.

## UUT-1

# UNIT UNDER TEST (UUT) SUMMARY SHEET



**Mounting Details:** Flexible floor mounted on 4 - AMC Mecanocaucho Marinelager S/N:136024 isolation devices. Each isolator connects to the UUT with one M16 Grade 8.8 bolt and mounts to the table with 2 - M12 Grade 8.8 bolts.



Manufacturer: KKT Chillers - AIT Deutschland GmbH

Component: cBoxX 100 | Model / Serial Number: | 909100-00469 / 91001235

UUT Function: Cools liquid using an air chilled refrigerant system

**UUT Description:** KKT Compact Chiller with 75kW net cooling capacity. Unit is floor mounted on vibration isolators as detailed above.

**Test Location:** IABG mbH, Germany **Test Date:** September 2017

### **UUT PROPERTIES**

Weight (lb)*		Dimensions (inches)	Natural Fequency (Hz)				
	Width	Depth	Height	FB	SS	V	
	1,740	32.7"	72.4"	79.9"	4.5	2.6	7.9

\*Weight includes normal operating fluid.

## SEISMIC TEST PARAMETERS

Building Code / Test Criteria	$S_{DS}(g)$	z / h	$I_{P}$	$A_{FLX-H}(g)$	$A_{RIG-H}(g)$	$A_{FLX-V}(g)$	$A_{RIG-V}(g)$
CBC 2016 / ICC-ES AC156	2.00	1.0	1.5	3.20	2.40		
CBC 2010 / ICC-ES AC130	2.50	0.0	1.5			1.67	0.67

Notes: <sup>1)</sup> The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. <sup>2)</sup> The unit maintained structural integrity during and after the ICC-ES AC156 Test. <sup>3)</sup> Modification to the base of the unit (add base plates - AIT drawing #P6856-0020) are required to address anomolies observed during the test.

## UUT-2

# UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid wall mounted with 3 - M8 Grade 8.8 bolts



Manufacturer: KKT Chillers - AIT Deutschland GmbH

Component: Chiller Interface Panel (CIP) Model / Serial Number: 909000.0107 / Z910701

**UUT Function:** Serves as Chiller Interface and Fluid Line connection

**UUT Description:** Component of cBoxX 100 Chiller configuration. Contains pressure gauges, manual shut off valve, flow meter, and thermometer.

#### **UUT PROPERTIES** Dimensions (inches) Natural Fequency (Hz) Weight (lb) Width Depth Height FB SS 25.4" 52.2" 171 13.6" 15.4 16.4 32.8 SEISMIC TEST PARAMETERS Building Code / Test Criteria $S_{DS}(g)$ z/h $I_{p}$ $A_{FLX-H}(g)|A_{RIG-H}(g)|A_{FLX-V}(g)|A_{RIG-V}(g)$ 2.00 1.0 1.5 3.20 2.40 CBC 2016 / ICC-ES AC156 2.50 0.0 0.67 1.5 1.67

Note: <sup>1)</sup> The unit was full of contents during testing and remained functional before and after the ICC-ES AC156 test. <sup>2)</sup> The unit maintained structural integrity during and after the ICC-ES AC156 Test.